

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034835 Discharge Number: 001

Facility: Pocahontas Water /sewer

Address: 207 Hwy 675

City: Pocahontas State: Ar Zip: 72455

Contact: Bruce Brodell Phone: 870-892-3222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits

We feel this problem was due to:

Chlorine feed problem / pump maintenance . Rainfall and River stage . Called testing labs and corrected Flow rate. re-submitted DMR after corrections.

We plan on correcting the problem in this manner:

Perform and correct Chlorine feeding rates, Called testing lab and corrected Flow rates.

Time estimated that it will take to correct problem:

Samples taken on 8/6/19 show that levels are in compliance

Sincerely,

Bruce Brodell  
Authorized Signature

8/20/19  
Date

**bbrodell@suddenlinkmail.com**

---

**From:** Effluent\_Exceedances\_Notification@epa.gov  
**Sent:** Monday, August 19, 2019 06:05 AM  
**To:** bbrodell@suddenlinkmail.com  
**Cc:** billgdaniel@outlook.com; ccherryppww@suddenlinkmail.com;  
pocmayor@cityofpocahontas.com  
**Subject:** ATTENTION REQUIRED: Discharge exceedance reported for AR0034835 submitted on 08/15/2019

Dear bruce brodell –

The purpose of this message is to notify you that **EPA's national NPDES data system has identified one or more effluent limit exceedances** for AR0034835 – POCAHONTAS, CITY OF that were reported on the Discharge Monitoring Report (DMR) signed on 08/15/2019.

NPDES permittees are responsible for ensuring full compliance with their permits, the Clean Water Act, and Arkansas Law. The Clean Water Act and Arkansas Law aim to protect clean water in your community. The Arkansas Department of Environmental Quality strongly encourages you to **take appropriate measures to ensure full compliance with your permit and the law.**

Information regarding this notification is given below. **You, as well as the public, can also view this information on EPA's public access website – Enforcement and Compliance History Online (ECHO) at: <https://echo.epa.gov/detailed-facility-report?fid=AR0034835&sys=ICP>.** Finally, you can also use this [link](#) to download the last three years of DMR data for AR0034835 – POCAHONTAS, CITY OF.

Please resubmit your DMR if you believe you provided inaccurate information on the DMR signed on 08/15/2019.

If you believe any of these effluent limit exceedances were mistakenly identified by EPA, please see the [Report Data Error guide](#) for how to submit this request through ECHO. If you have general inquiries regarding this message, or wish to discuss expediting your return to compliance, you can contact your NPDES permitting authority at (501) 682-0624 or by email at [WaterEnforcement@adeq.state.ar.us](mailto:WaterEnforcement@adeq.state.ar.us).

Thank you,  
Arkansas Department of Environmental Quality  
Office of Water Quality, Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

#### **Summary of Effluent Limit Exceedances**

Permit Name: POCAHONTAS, CITY OF, POCAHONTAS, AR, 72455

Permit Number: AR0034835

Permit Effective Date & Expiration Date: 05/01/2019 & 04/30/2024

DMR Signer: bruce brodell

Permitted Feature ID, Limit Set Designator, Monitoring Period End Date, Monitoring Location, Parameter, and Value Type are the columns that uniquely identify the effluent limit exceedance. Please reference your Permit Number and the information in this table if you have questions regarding any single exceedance detailed below.

Permitted Feature ID	Limit Set Designator	Monitoring Period End Date	Monitoring Location	Parameter	Value Type	Statistical Base Short Desc	DMR Value	Limit Value	Exceedence %
001	A	07/31/2019	1 - Effluent Gross	00310 - BOD, 5-day, 20 deg. C	Q1 - Quantity1	MO AVG	= 178.2 lb/d	<= 171.1 lb/d	4
001	A	07/31/2019	1 - Effluent Gross	74055 - Coliform, fecal general	C2 - Concentration2	30DA GEO	= 288 #/100mL	<= 200 #/100mL	44
001	A	07/31/2019	1 - Effluent Gross	74055 - Coliform, fecal general	C3 - Concentration3	7 DA GEO	= 5837 #/100mL	<= 400 #/100mL	1359

POCAHONTAS WATER & SEWER SYSTEMS  
207 HIGHWAY 67 SOUTH  
POCAHONTAS, ARKANSAS 72455  
892-3222

72118-3801

ADEQ  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock Ar 72118

22 AUG 2019 PM 2 L

MEMPHIS TN 380

REVER / USA

