

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0034835 Discharge Number: 001-A

Facility: CITY OF POCAHONTAS WWTP

Address: 207 HWY 67 S

City: POCAHONTAS

State: AR

Zip: 72455

Contact: Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
MARCH	TSS MONTHLY AVERAGE	238.4		171.1

We feel this problem was due to:

Lot of rainfall, infiltration, high flow during this period.

We plan on correcting the problem in this manner:

repairing more lines in our system

Time estimated that it will take to correct problem:

The process will be ongoing. Always working to improve the system.

Sincerely,

Bruce Bodell

Submitted By:

Date

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

POCAHONTAS WATER & SEWER SYSTEMS

207 HIGHWAY 67 SOUTH
POCAHONTAS, ARKANSAS 72455
892-3222

MEMPHIS TN 380

24 APR 2022 6:14 PM



ADEQ
Office of Water Quality - Enforcement
5301 Northshore Dr
North Little Rock Ar 72118

72118-531799

