

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0034835 Discharge Number: 001-A

Facility: CITY OF POCAHONTAS WWTP

Address: 207 HWY 67 S

City: POCAHONTAS State: AR Zip: 72455

Contact: Bruce Brodell Phone: 870-892-3222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
JULY	FECAL 30 DAY GEO		204.0	200.0
7/17/23	FECAL 7 DAY GEO		1550.0	400.0

We feel this problem was due to:

The chlorine residual maybe not what it should be at that time

We plan on correcting the problem in this manner:

monitor and try to correct the problem

Time estimated that it will take to correct problem:

We will work on it immediately to try to correct the problem

Sincerely,

Bruce Brodell

8/23/23
Date

Submitted By:

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)