

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0034835

Discharge Number: 001-A

Facility: CITY OF POCAHONTAS WWTP

Address: 207 HWY 67 S

City: POCAHONTAS

State: AR

Zip: 72455

Contact: Bruce Brodell

Phone: 870-892-3222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/1/22	pH MAXIMUM		9.51	9.0
11/8/22	pH MAXIMUM		9.14	9.0
11/16/22	pH MAXIMUM		9.05	9.0

We feel this problem was due to:

Still seems to be an algae problem. Unusual low rainfall and drought conditions. The lagoon levels are rising and the effluent flow is getting back to normal.

We plan on correcting the problem in this manner:

We have been receiving large amounts of rain in December. The PH numbers are coming down in recent samples. Also talked to Mrs. Frazier with ADEC and explained the situation.

Time estimated that it will take to correct problem:

The Ph is coming down. We believe with recent rains and colder temperatures the problem is naturally taking care of itself.

Sincerely,

Bruce Brodell

12/16/22

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)