

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0034835 Discharge Number: 001-A

Facility: CITY OF POCAHONTAS WWTP

Address: 207 HWY 67 S

City: POCAHONTAS State: AR Zip: 72455

Contact: Bruce Brodell Phone: 870-892-3222

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10/3/22	pH MAXIMUM		9.56	9.0
10/18/22	pH MAXIMUM		9.68	9.0

We feel this problem was due to:

Seems like possibly still algae

We plan on correcting the problem in this manner:

Seeing if colder temps and more frequent rain will solve the problem.

Time estimated that it will take to correct problem:

I have been looking back at previous reports. Looks like the problem has been in the last (2) months. Keeping an eye on the problem.

Sincerely,

Bruce Brodell

11/18/22

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)