

Sanitary Sewer Overflow Monthly Report

Facility Name: Pocahontas Water & Sewer Systems Permit Number: AR0034835 Reporting Period (Month/Year): SEPTEMBER 2013.

No Sanitary Sewer Overflow This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action (s) taken	Ultimate Discharge Location
Co-Construction	D-Debris	NEAH- No Evidence of Adverse Health or Environmental Impact	WO-Work Order
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	DI-Ditch
R-Rainfall	RG-Roots & Grease	HR-Hand Rodded	DR-Drop Inlet
R-Roots	V-Vandalism	EN-Referred to Engineering	GR-Ground Surface
		PN-Public Notification	PA-Paved Area
			CB-Contained in building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (In gallons)	Cause of SSO	Environment Impact	Action(s) Taken To Address SSO	Ultimate Discharge Location
909 N. PRATT		09/19/13	09/19/13	50	RG	NEAH	HC	BLACK RIVER
1302 PACE		09/30/13	09/30/13	100	RG	NEAH	HC	BLACK RIVER
1239 W. MARR		09/30/13	09/30/13	150	RG	NEAH	HC	BLACK RIVER
1203 PAYNE		09/25/13	09/25/13	100	RG	NEAH	HC	BLACK RIVER

Signature of Cognizant or Ranking Official William H Daniel

OCTOBER 16, 2013

I certify under penalty of law that the document and all attachment were prepared under my direction or supervision in accordance with a system designed to assure that qualified personal Properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the Information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information Including the possibility of fine and imprisonment for knowing violations.

POCAHONTAS WATER & SEWER SYSTEMS
207 HIWAY 67 SOUTH
POCAHONTAS AR
72455
(870) 892-3222

ADEQ
8001 NATIONAL DRIVE
POST OFFICE BOX 8913
LITTLE ROCK, AR. 72219-8913

Report of Non-Compliance

Name of Facility: Pocahontas Water & Sewer Systems

Permit Number: AR0034835

Date of Violation: 09/01/13-----09/30/13

Parameter Violated: FECAL/7 DAY GEO

Reporter Violation 759.0

Permit Condition 400.0

Cause of Violation: CHLORINE DISCHARGE LINE STOPPPED UP

Duration of Violation: WEEK OF 09/17/13

Corrective Action: REMOVED AND CLEAN LINE

Expected Compliance Data:

Signature: 

WILLIAM G. DANIEL, Manager



ADEQ
NPDES Enforcement
5301 Northshore Drive
North Little Rock, AR 72118

72118531799

