

**POCAHONTAS WATER & SEWER SYSTEMS
207 HIWAY 67 SOUTH
POCAHONTAS AR
72455
(870) 892-3222**

**ADEQ
8001 NATIONAL DRIVE
POST OFFICE BOX 8913
LITTLE ROCK, AR. 72219-8913**

Report of Non-Compliance

Name of Facility: Pocahontas Water & Sewer Systems

Permit Number: AR0034835

Date of Violation: 06/01/2016-----06/13/2016

Parameter Violated: C/BOD-----TSS

Reporter Violation 355.9 856.5

Permit Condition 171.0 514.0

Cause of Violation: HEAVY RAINS, FOOD, INFILTRATION

Duration of Violation: WEEK OF 06/13/2016

Corrective Action: HEAVY RAINS STOPPED, WATER WENT DOWN,
INFILTRATION STOPED


Expected Compliance Data:

Signature: _____

WILLIAM G. DANIEL, Manager

MEMPHIS TN 381

02 AUG 2016 PM 4 1



ADEQ
NPDES ENFORCEMENT

5301 Northshore Drive
North Little Rock, AR 72118

72118-532801

