

REPORT OF NON COMPLIANCE

NAME OF FACILITY POCAHONTAS, CITY OF

PERMIT NUMBER AR0034835 001-A

PERIOD ENDING September 2015

PARAMETER VIOLATED	NO SAMPLE						
REPORTED VIOLATIONS	NODI G						
PARAMETER VIOLATED	NODI G						

WEEK OF

Please fill out the following information

CAUSE OF VIOLATION Per Bill Daniels, meter out of order. Therefore, we are unable to calculate flow, loading and averages.

EFFLUENT METER WENT OUT 8/24/15

DURATION OF VIOLATION 8/24/15 - 9/15/15

CORRECTIVE ACTION Replaced effluent meter with new one

EXPECTED COMPLIANCE DATE new meter installed 9/14/15

William M Daniels
SIGNATURE / DATE

MEMPHIS TN 380

20 OCT 2015 PM 11



ADEQ
NPDES Enforcement
5301 Northshore Drive
North Little Rock, AR 72118

72118-531799

