



December 14, 2018

Honorable Barbara Lewallen
Mayor, City of Trumann
704 Highway 463 North
Trumann, AR 72472

email: citytrumann72472@yahoo.com

RE: NPDES Permit Number AR0035602, AFIN 56-00047
NPDES Permit Effluent Violations

Dear Mayor Lewallen,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting periods.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
08/31/2016	001-A	pH, MAXIMUM, SU	9	9.2	%

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0649 or you may e-mail me at rathe@adeq.state.ar.us.

Sincerely,

Rebecca Rathe
Enforcement Analyst
Office of Water Quality