

# ADEQ

ARKANSAS  
Department of Environmental Quality

September 26, 2013

Scotty Jones  
106 East Main Street  
Trumann, AR 72472

RE: NPDES Permit Number AR0035602, AFIN 56-00047  
NPDES Permit Effluent Violations


Dear Mr. Jones,

A recent review of the NPDES file for the above referenced facility for the period of July 1, 2013 through August 30, 2013 reveals the effluent violations found in Attachment A.

Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0823 or e-mail at [suel@adeq.state.ar.us](mailto:suel@adeq.state.ar.us).

Sincerely,



Kevin Suel  
Enforcement Analyst  
Water Division, Enforcement Branch

Attachment A

**Effluent Violations (E90) Since 7/1/13**  
**TRUMANN, CITY OF-WWTP - AR0035602 (56-00047)**

DMR End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
08/31/2013	001-A	Solids, total suspended, 7 DA AVG, mg/L	135.	205	52%