

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0035602 Discharge Number: 56.00047
Facility: TRUMANN WATER WORKS
Address: 106 E MAIN ST.
City: TRUMANN State: AR Zip: 72472
Contact: SCOTTY JONES Phone: 870.483-6343

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>08/02/2014</u>	<u>PH</u>		<u>9.2 mg/L</u>	<u>6.0 mg/L - 9.0 mg/L</u>

We feel this problem was due to:
Heat, extreme algae growth, & low freeboard

We plan on correcting the problem in this manner:
OUR SOP DURING SUMMER MONTHS WHEN PH MAY RISE IS NOT TO DISCHARGE, RECYCLE OUR WATER BACK THROUGH THE PROCESS, & MONITOR PH UNTIL WE FEEL CERTAIN IT IS AT ACCEPTABLE LEVELS

Time estimated that it will take to correct problem:
WE ARE CURRENTLY WITHIN OUR PERMITTED LIMITS

Sincerely,


09/15/2014

Authorized Signature

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)