## Allen-Daniel, Leslie

From: Lorre Holt <lorre\_holt0201@yahoo.com>

Sent: Tuesday, March 8, 2022 2:53 PM

To: Allen-Daniel, Leslie
Cc: Public Works Director

**Subject:** Fwd: AR0035602-C. DUBIA WET LIMIT-PROGRESS REPORT # 1

**Attachments:** 1392859.pdf; ATT00001.htm; 1407414.pdf; ATT00002.htm; 1420781.pdf; ATT00003.htm;

1436291.pdf; ATT00004.htm; 1439758.pdf; ATT00005.htm; 1445766.pdf; ATT00006.htm

Sent from my iPhone

Begin forwarded message:

From: LORRE HOLT < lorre holt0201@yahoo.com>

**Date:** January 27, 2022 at 11:47:14 AM CST **To:** water-enforcement-report@adeq.state.ar.us

Cc: Public Works Director < director@cityoftrumann.org>

Subject: AR0035602-C. DUBIA WET LIMIT-PROGRESS REPORT # 1

C.DUBIA WET LIMIT-PROGRESS REPORT #1

AMERICAN INTERPLEX REPORT CONTROL NO 251995-1 -- 1/22/21 BIOMONITORING TESTING

THE C. DUBIA PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS. THE FATHEAD MINNOW PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS.

AMERICAN INTERPLEX REPORT CONTROL NO 254899-1-- 5/5/21 BIOMONITORING TESTING

THE C. DUBIA PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS. THE FATHEAD MINNOW PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS.

AMERICAN INTERPLEX REPORT CONTROL NO 257320-1-- 8/5/21 BIOMONITORING TESTING

THE C. DUBIA PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS. THE FATHEAD MINNOW PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS.

AMERICAN INTERPLEX REPORT CONTROL NO.259819- 1--11/8/21 BIOMONITORING TESTING THE C. DUBIA PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS. THE FATHEAD MINNOW PASSED

LETHAL HOWEVER FAILED SUB-LETHAL EFFECTS. WHICH INITIATED THREE ADDITIONAL TEST FOR THE FATHED MINNOW.
AMERICAN INTERPLEX REPORT CONTROL NO 260408-1 11/30/21 BIOMONITORING FATHEAD RETEST # 1 FATHEAD MINNOW PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS.
AMERICAN INTERPLEX REPORT CONTROL NO 261164-1 12/30/21 BIOMONITORING FATHEAD RETEST # 2 FATHEAD MINNOW PASSED BOTH LETHAL AND SUB-LETHAL EFFECTS
FATHEAD RETEST # 3 SAMPLES WERE SHIPPED FOR ANALYSIS THE WEEK OF 1/16/22 WE DON NOT HAVE THE RESULTS YET.
THANK YOU
LORRE HOLT
TRUMANN WATER WORKS