

**LOST BRIDGE VILLAGE WATER AND SEWER IMPROVEMENT DISTRICTS
WASTEWATER TREATMENT PLANT
FLOW RECORD AND EFFLUENT CONCENTRATION**

AR0036676

Benton

August 2013

NPDES ID #

County

Month and Year

METER READING Previous Read 305,957.30 V-Notch weir	DATE	1000 GALLONS TREATED	EFFLUENT CONCENTRATION						RESIDUAL	
			CLORINE RES.		NH3		PHOS		PH VALUE	INITIALS
			LBS	MG/L	ALK	MG/L		MG/L		
	1	26,280	1.0	0.60	60.0	0.20		0.1	7.2	DK
	2	18,570	1.0	0.55	45.0	0.20		0.1	7.0	DK
	3	28,950	1.0	0.74	50.0	0.20		0.4	6.8	
	4	32,400	1.0	0.80	80.0	0.20		0.3	7.4	
	5	38,880	1.0	1.12	100.0	0.80		0.2	6.1	
	6	57,240	1.0	0.70	75.0	0.80		0.8	7.0	
	7	75,110	1.0	0.48	40.0	0.60		0.4	6.9	
	8	98,200	1.0	0.32	30.0	0.45		0.5	7.2	
	9	70,140	1.0	0.45	20.0	0.80		0.3	7.0	
	10	59,450	1.0	0.79	45.0	1.15		0.45	7.1	
	11	60,710	1.0	0.82	70.0	2.00		0.20	6.0	
	12	48,200	1.0	0.98	85.0	1.85		0.20	6.0	
	13	50,180	1.0	1.12	60.0	1.40		0.20	7.1	
	14	42,460	1.0	0.44	45.0	0.2		0.01	7.0	
	15	39,180	1.0	0.60	60.0	0.2		0.10	6.8	
	16	28,290	1.0	0.70	45.0	0.2		0.2	7.2	
	17	26,280	1.0	0.45	70.0	0.2		0.3	7.0	
	18	23,550	1.0	0.70	70.0	0.2		0.1	6.5	
	19	28,140	1.0							
	20	29,470	1.0	1.52	75.0	0.2		0.3	6.0	
	21	24,180	1.0	1.15	75.0	0.2		0.2	6.0	
	22	22,660	1.0	1.95	50.0	0.2		0.3	6.5	
	23	20,180	1.0	0.85	45.0	0.2		0.45	6.5	
	24	23,200	1.0	0.95	55.0	0.2		0.30	6.5	
	25	20,180	1.0	0.70	60.0	0.2		0.20	6.5	
	26	24,260	1.0	0.90	65.0	0.2		0.10	6.5	
	27	23,010	1.0	0.20	50.0	0.2		0.40	7.0	
	28	20,690	1.0	0.85	50.0	0.2		0.30	7.0	
	29	21,800	1.0	0.22	80.0	0.2		0.83	7.0	
	30	24,260	1.0	0.42	70.0	0.2		0.90	6.0	
	31	27,540	1.0	0.30	55.0	0.2		0.45	6.7	
	TOT	1138640								
	AVG	36.730								
	MAX	98,200								
	MIN	18,570								

I certify that the information in this report is true and accurate to the best of my knowledge. I acknowledge that any knowingly false or misleading information may be punishable under 18 USC 1001 and other applicable laws.

Printed Name Danny Howard Signature Danny Howard Date 9-3-13

Put any notes or comments on reverse side; make a copy for your records.

Return by the 10th of the following month to: ADH/Engineering Section, 4815 West Markham, Slot H-37, Little Rock, AR 72205-3867

Totalizer meter not working
Taking 3 measurements per day - averaging 3 measurements
(Note)

Sanitary Sewer Overflow Monthly Report

City Name: LBV Water & Sewer Permit Number: Ar 00036676

Reporting Period (Month/Year): Aug 2013

Yes ☒ No ☐ Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

<u>Cause(s) of SSO</u>		<u>SSO Impact</u>	<u>Action(s) Taken</u>	<u>Ultimate Discharge Location</u>
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order,	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line -	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	Failure/Break		HR-Hand Rodded	GR-Ground Surface
RO-Roots	RG-Roots & Grease		EN-Referred to Engineering	PA-Paved Area
	V-Vandalism		PN-Public Notification	CB-Contained in Building
<u>Location</u>	<u>Manhole Number</u>	<u>Start Date of SSO</u>	<u>End Date of SSO</u>	<u>Estimated Volume in gallons</u>

<u>Cause of SSO</u>	<u>Environmental Impact</u>	<u>Action(s) Taken to Address SSO</u>	<u>Ultimate Discharge Location</u>


Signature of Cognizant or Ranking Official

9/5/13
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."



Environmental Services Company, Inc.

1107 Century
Springdale, AR 72762
479-750-1170 Fax: 479-750-1172

NORTHWEST AR P&DF
AR 727 2 T
03 OCT 2013 PM



ADEQ
WATER DIVISION, PERMITS
5301 NORTHSORE DR.
NORTH LITTLE ROCK AR 72118

7211835317

