

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0036692 Discharge Number: 001
Facility: Mena WWTP
Address: 323 Polk 53
City: Mena State: Ar Zip: 71953
Contact: Mike Spencer Phone: 4792342592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4/12/24	CU	241 ug/l	10000	10.5 ug/l

We feel this problem was due to:

~~The City feels must be a lab error as sample reads 10000 ug/l. If is correct the City has no copper removal process.~~

We plan on correcting the problem in this manner:

~~Plan on investigating into the sample and more samples delivered to a second lab.~~

Time estimated that it will take to correct problem:

~~Unknown~~

Sincerely,


Submitted By: _____

14 MAY 2024
Date _____

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)