

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0036692

Discharge Number: 001

Facility: Mena WWTP

Address: 323 Polk 53

City: Mena

State: Ar

Zip: 71953

Contact: Shaun Wyman

Phone: 479-234-5167

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8/8/2024	Dissolved Oxygen (DO)		6.8	7.1 mg/L (min)
8/9/2024	Dissolved Oxygen (DO)		6.7	7.1 mg/L (min)
8/15/2024	Dissolved Oxygen (DO)		6.6	7.1 mg/L (min)
8/16/2024	Dissolved Oxygen (DO)		6.8	7.1 mg/L (min)

We feel this problem was due to:

~~I feel the cause of the exceedance is algal respiration and large excess of sludge~~

We plan on correcting the problem in this manner:

~~the city continuing makes progress toward constructing a new water treatment facility~~

Time estimated that it will take to correct problem:

~~all resolutions will be completed as soon as possible~~

Sincerely,

Submitted By:

Date

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0036692

Discharge Number: 001

Facility: Mena WWTP

Address: 323 Polk 53

City: Mena

State: Ar

Zip: 71953

Contact: Shaun Wyman

Phone: 479-234-5167

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8/8/2024	Ammonia Nitrogen		4.7	4.5 max
8/29/2024	Dissolved Oxygen (DO)		7.0	7.1 mg/L (min)
8/30/2024	Dissolved Oxygen (DO)		6.9	7.1 mg/L (min)

We feel this problem was due to:

We plan on correcting the problem in this manner:

Time estimated that it will take to correct problem:

Sincerely,

Submitted By: _____

Date: _____

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)