

## NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment  
Division of Environmental Quality  
Office of Water Quality, Enforcement Section  
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: ar0036692 Discharge Number: 001  
Facility: Mena WWTP  
Address: 323 polk 53  
City: Mena State: Ar Zip: 71953  
Contact: Mike Spencer Phone: 4792342592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
April 5,11,12	DO	6.1/6.8/6.9	6.1/6.8/6.9	7.1

We feel this problem was due to:

The City feels like excessive sludge and insufficient mixing and short circuiting and soluble BOD is consuming the oxygen

We plan on correcting the problem in this manner:

No official plans for sludge removal

Time estimated that it will take to correct problem:

Unknown

Sincerely,

  
Submitted By: \_\_\_\_\_

14 MAR 2024  
Date \_\_\_\_\_

☐ Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

## NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment  
Division of Environmental Quality  
Office of Water Quality, Enforcement Section  
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: ar0036692 Discharge Number: 001  
Facility: Mena WWTP  
Address: 323 Polk 53  
City: Mena State: Ar Zip: 71953  
Contact: Mike Spencer Phone: 4792342592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4/11/24	PAA	1.1 mg/l	1.1 mg/l	1.0 mg/l

We feel this problem was due to:

~~The plant has no way of monitoring PAA with auto adjusting pumps that could monitor dose compared to flow.~~

We plan on correcting the problem in this manner:

~~The City currently has no official plans to correct this issue.~~

Time estimated that it will take to correct problem:

~~unknown~~

Sincerely,

  
Submitted By: \_\_\_\_\_

14 MAY 2024  
Date \_\_\_\_\_

☐ Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)