## NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment Division of Environmental Quality Office of Water Quality, Enforcement Section 5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: ARO	036692	Di	Discharge Number: Outfall 001		
Facility: City of Mena	- Mena Wastewater Treatment Pl	lant			
Address: 323 Polk 53					
City: Mena		State: Arkans	State: Arkansas Zip: 71953		
Contact: James Loo	ney, General Manager, Mena Wa	ster Utilities Phone:	(479) 394-2761		
Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits	
8/2/2023	Dissolved Oxygen (DO)		7.00 mg/L	7.1 mg/L (Min.)	
8/3/2023	Dissolved Oxygen (DO)		6.74 mg/L	7.1 mg/L (Min.)	
8/16/2023	Dissolved Oxygen (DO)		7.02 mg/L	7.1 mg/L (Min.)	
8/17/2023	Dissolved Oxygen (DO)		6.83 mg/L	7.1 mg/L (Min.)	
	ng the problem in this man		er treatment facility, whic	h is expected to	
provide more operation	al flexibility and be less susceptib	ole to permit excursion	s occurring at the existing	ng facility.	
	it will take to correct problems. I be completed as soon				
es week to be the	electronically via N	Date letDMR	9.5-2023	d under my diseasion	

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)