



August 4, 2021

EMAIL

Ms. Sarah Pierce, Enforcement Analyst
Arkansas Division of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Mena Water Utilities
NPDES Permit Number: AR0036692, AFIN-57-00423, CAO LIS 18-046
Notification of Permit Exceedance

Dear Ms. Pierce:

This letter is intended to provide notification of a permit exceedance that was recorded at the City of Mena's Wastewater Treatment Plant (WWTP) during the month of July 2021. The Permit exceedance and its associated sampling date is provided below.

Sampling Date
July 21, 2021

Constituent Out of Compliance
Fecal Coliforms

The cause of the recorded Fecal Coliform exceedance is expected to be a result of a clog in the PAA disinfection dose line currently being used during the trial study. After flushing the discharge line and performing minor pump maintenance, the system is operating as intended.

Respectfully Submitted,

HAWKINS-WEIR ENGINEERS, INC.

A handwritten signature in blue ink that reads 'Elizabeth Heiles'.

Elizabeth S. Heiles, P.E.

ESH/vrg

cc: Mr. Mike Spencer, Mena Water Utilities Wastewater Superintendent