



August 1, 2022

EMAIL

Ms. Jill Gray, Enforcement Analyst  
Arkansas Division of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

Re: Mena Water Utilities  
NPDES Permit Number: AR0036692, AFIN-57-00423, CAO LIS 18-046  
Notification of Permit Exceedance

Dear Ms. Gray:

This letter is intended to provide notification of a permit exceedance that was recorded at the City of Mena's Wastewater Treatment Plant (WWTP) during the month of July 2022. The permit exceedance and its associated sampling date is provided below.

Sampling Date  
July 7, 2022

Constituents Out of Compliance  
Dissolved Oxygen (DO)

The cause of the recorded DO exceedance is unknown but is suspected to be a result of algal respiration within the lagoons. As referenced in the City's Effluent Limits Compliance Quarterly Progress Report No. 11 submitted to the DEQ on July 15, 2022, the city is continuing to make progress toward constructing a new activated sludge wastewater treatment facility. This new facility is expected to provide more operational flexibility and be less susceptible to the permit excursions occurring at the city's existing facility.

Respectfully Submitted,

HAWKINS-WEIR ENGINEERS, INC.

A handwritten signature in black ink, appearing to read 'Adrian J. Kaufman', is written over the printed name.

Adrian J. Kaufman, P.E.

AJK/snt

cc: Mr. James Looney, Mena Water Utilities General Manager  
Mr. Mike Spencer, Mena Water Utilities Wastewater Superintendent