

## NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment  
 Division of Environmental Quality  
 Office of Water Quality, Enforcement Section  
 5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0036692 Discharge Number: 001  
 Facility: Mena WWTP  
 Address: 323 Polk 53  
 City: Mena State: Ar Zip: 71953  
 Contact: Mike Spencer Phone: 4792342592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
21March24	PH	5.9		6.0
22Mar24	PH	5.2		6.0
27Mar24	PH	5.9		6.0
28march	PH	5.9		6.0

We feel this problem was due to:

~~Excessive I and I and chemical used for treatment. Our chemical alum has a very low PH(2.9SU). The rain was tested at 5.0 SU and we are recieving over 3.5 MG of I and I water after rain events lasting up to 2 weeks.~~


We plan on correcting the problem in this manner:

~~Currently no official plans to correct~~

Time estimated that it will take to correct problem:

~~Unknown~~

Sincerely,

  
 Submitted By:

9 Apr 2024  
 Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

## NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment  
 Division of Environmental Quality  
 Office of Water Quality, Enforcement Section  
 5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: ar0036692 Discharge Number: 001  
 Facility: Mena WWTP  
 Address: 323 Polk 53  
 City: Mena State: Ar Zip: 71953  
 Contact: Mike Spencer Phone: 4792342592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3/22/24	DO		6.8mg/l	7.1

We feel this problem was due to:

~~Believe with excess sludge levels (around 5 foot deep) that there is inadequate mixing and the soluble BOD of sludge is robbing water of oxygen.~~

We plan on correcting the problem in this manner:

~~No official plans to boost DO~~

Time estimated that it will take to correct problem:

~~Unknown~~

Sincerely,

  
 Submitted By: \_\_\_\_\_

1 Apr 24  
 Date \_\_\_\_\_

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)