

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0036692 Discharge Number: Outfall 001

Facility: City of Mena - Mena Wastewater Treatment Plant

Address: 323 Polk 53

City: Mena State: Arkansas Zip: 71953

Contact: James Looney, General Manager, Mena Water Utilities Phone: (479) 394-2761

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/10/2023	pH		5.6 s.u.	6.0 s.u. (Min.)
5/11/2023	pH		5.6 s.u.	6.0 s.u. (Min.)

We feel this problem was due to:

The cause of the pH exceedances is unknown, but may have been caused by higher than normal Alum concentrations.


We plan on correcting the problem in this manner:

The City is continuing to make progress toward constructing a new wastewater treatment facility, which is expected to provide more operational flexibility and be less susceptible to permit excursions occurring at the existing facility.

Time estimated that it will take to correct problem:

All resolutions will be completed as soon as possible.

Sincerely,



Submitted By:

Date: 5/25/2023

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)