

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: ar0036692 Discharge Number: 001

Facility: Mena WWTP

Address: 323 Polk road 53

City: Mena State: Ar Zip: 71953

Contact: WWTP Supervisor Phone: 479-394-2761

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
8/12/2020	TSS	34	34	22.5

We feel this problem was due to:

~~During bypass treatment cannot be met to permit parameter~~

We plan on correcting the problem in this manner:

~~Correct I and I~~

Time estimated that it will take to correct problem:

~~1 to 7 years~~

Sincerely,

M D Spencer

09/11/20

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)