

MENA WASTEWATER TREATMENT PLANT- AR003662
323 POLK 53, MENA AR, 71953
PHONE 479-394-1239 FAX 479-394-5053

February 2018

VIOLATION EXPLANATION

PERMITTEE: City of Mena Wastewater Treatment Plant

DATES OF VIOLATION: Week 21/22 Feb 2017

PARAMETR VIOLATED: Weekly TSS


REPORTED DISCHARGE: TSS

This violation letter is to inform your office Mena Wastewater Treatment Plant has exceeded its discharge limit for the month of Feb 2017 on the following parameters.

	Reported Value	Permit Limit
A. TSS Weekly	23	22.5

The TSS violation is week of 18-24 February 2017. The total effluent discharge was approximately 6 mgd. Excessive I and I is reason for violation. Plant is rated at 3.1 MGD, and with I and I rates exceeding rated plant maximum just cannot filter and treat these volumes.

Sincerely;


Mike Spencer
Plant Supervisor

Cc: Charles Pitman, Manager