

**MENA WASTEWATER TREATMENT PLANT- AR003662**  
323 POLK 53, MENA AR, 71953  
PHONE 479-394-1239 FAX 479-394-5053

*February 2018*

**VIOLATION EXPLANATION**

**PERMITTEE:** City of Mena Wastewater Treatment Plant

**DATES OF VIOLATION:** Week 21/22 Feb 2018

**PARAMETR VIOLATED:** Weekly TSS


**REPORTED DISCHARGE:** TSS

This violation letter is to inform your office Mena Wastewater Treatment Plant has exceeded its discharge limit for the month of Feb 2018 on the following parameters.

	Reported Value	Permit Limit
<b>A. TSS Weekly</b>	<b>23</b>	<b>22.5</b>

The TSS violation is week of 18-24 February 2017. The total effluent discharge was approximately 6 mgd. Excessive I and I is reason for violation. Plant is rated at 3.1 MGD, and with I and I rates exceeding rated plant maximum just cannot filter and treat these volumes.

Sincerely;

  
Mike Spencer  
Plant Supervisor

Cc: Charles Pitman, Manager

**MENA WASTEWATER TREATMENT PLANT- AR003662**  
323 POLK 53, MENA AR, 71953  
PHONE 479-394-1239 FAX 479-394-5053

**March 2018**

**VIOLATION EXPLANATION**


**PERMITTEE:** City of Mena Wastewater Treatment Plant  
**DATES OF VIOLATION:** Week 11-17 March 2018  
**PARAMETER VIOLATED:** Weekly TSS  
**REPORTED DISCHARGE:** TSS

This violation letter is to inform your office Mena Wastewater Treatment Plant has exceeded its discharge limit for the month of Mar 2018 on the following parameters.

	Reported Value	Permit Limit
<b>A. TSS Weekly</b>	<b>27.5</b>	<b>22.5</b>

The TSS violation is week of 11-17 March 2018. The total effluent discharge was approximately 10mgd. Excessive I and I is reason for violation. The large rain event of 19 inches ended 1 March 2018 but with the City's I and I rate was still exceeding plant capacity 15 days after rain has stopped. Plant is rated at 3.1 MGD, and with I and I rates exceeding rated plant maximum just cannot filter and treat these volumes.

Sincerely;

  
Mike Spencer  
Plant Supervisor

Cc: Charles Pitman, Manager