

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: Ar00036692

Discharge Number: 001

Facility: Mena WWTP

Address: 323 Polk road 53

City: MenA

State: AR

Zip: 71953

Contact: \_\_\_\_\_

Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7/8/2019-7/9/2019	Dissolved oxygen	7.0/7.0		7.1

We feel this problem was due to:

~~Insufficient mixing in lagoon 1 with excessive sludge and short retention time.~~

We plan on correcting the problem in this manner:

~~Currently no sludge management plan in place~~

Time estimated that it will take to correct problem:

~~10/12 years~~

Sincerely,



Submitted By: \_\_\_\_\_

8/12/2019

Date \_\_\_\_\_

☒ Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: ar0036692 Discharge Number: 001

Facility: Mena WWTP

Address: 323 Polk 53

City: Mena State: Ar Zip: 71953

Contact: Mike Spencer Phone: 479-234-\*2592

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7/8/19-7/9/2019	PH	5.9/5.8		6.0

We feel this problem was due to:

~~Acidic Rain and excessive I and I mainly from rains in June 2019 along with acidic alum-  
as coagulant drop ph in lagoons to a point below permit~~

We plan on correcting the problem in this manner:

~~Correct I and I.~~

Time estimated that it will take to correct problem:

~~8 Years~~

Sincerely,

  
Submitted By:

13 Aug 19  
Date

☒ Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)