

Kristen Graham (adpce.ad)

To: Leslie Allen-Daniel (adpce.ad)
Cc: Richard Healey (adpce.ad)
Subject: RE: 2020024 - Mena WWTP - Unanticipated Bypass

From: Wes Lemonier [<mailto:Wes.Lemonier@hawkins-weir.com>]
Sent: Wednesday, December 14, 2022 4:48 PM
To: Jill Gray (adpce.ad)
Cc: A.J. Kaufman; Mike Spencer - Mena Water (menawwtp@gmail.com)
Subject: 2020024 - Mena WWTP - Unanticipated Bypass

Jill,

The City of Mena is currently in the middle of an unanticipated bypass at their WWTP due to the high volume of inflow and infiltration being conveyed by their collection system from recent rain events. The bypass began at 8:30 A.M. this morning and they have collected samples. We will provide a follow-up to this email with a formal notification once the final volume can be estimated. Copies of the laboratory test results will also be provided to DEQ.

Please let me know if you have any questions or need any additional information.

Thanks,

Wes LeMonier, P.E.

Office: (479) 474-1227

Mobile: (479) 883-6578

Fax: (479) 474-8531

e-mail: wes.lemonier@hawkins-weir.com

110 So. 7th Street P.O. Box 648

Van Buren, Arkansas 72956

