



March 7, 2019

Ms. Bailey Taylor, Enforcement Analyst
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: NPDES Permit Number: AR0036692, AFIN-57-00423
Report of Unanticipated Bypass from WWTP

Dear Ms. Taylor:

An unanticipated bypass occurred at the Mena WWTP beginning at 4:00 pm on February 23, 2019 and concluding at 8:30 am on February 25, 2019. Approximately 7,500,000 gallons of partly treated wastewater were discharged during this event.

As described by the Modified Corrective Action Plan (CAP - CAO LIS 18-046) submitted on February 28, 2019, the equalization capacity of Mena's wastewater treatment lagoons can be exhausted by the unusually high volume of I/I conveyed by their collection system during and immediately following wet weather events. The Interim Operations Plan in the CAP describes steps that the City must take to protect their WWTP until a long-term solution to this problem can be identified and implemented. To prevent damage from lagoon overflow, a bypass valve that directs partly treated wastewater from Lagoon #2 to a point near Outfall #1 must be opened. During these events, the City records the volume bypassed and collects samples from the bypass stream for analysis. Copies of the laboratory results related to this unanticipated bypass will be provided separate from this notification.

Hawkins-Weir Engineers, Inc. is in the process of preparing a Wastewater Treatment Masterplan that will identify a solution to the facility's peak flow capacity limitation. Per the terms of the Modified CAP, a copy of that report will be submitted to ADEQ by no later than September 1, 2019. Unanticipated bypasses could continue at the Mena WWTP until construction of the recommended improvements are completed by June 2023.

Respectfully Submitted,

HAWKINS-WEIR ENGINEERS, INC.

A handwritten signature in black ink that reads "Aaron Benzing". The signature is written in a cursive style with a long, sweeping underline.

Aaron M. Benzing, P.E.

AMB/hcd


cc: Mr. Charles Pitman, Mena Water Utilities General Manager

110 So. 7th Street • P.O. Box 648 • Van Buren, AR 72957 • Ph: (479) 474-1227 • Fax: (479) 474-8531
211 Natural Resources Drive • Little Rock, AR 72205 • Ph: (501) 374-4846
438 East Millsap Road • Suite 107 • Fayetteville, AR 72703 • Ph: (479) 455-2206
403 Garrison Avenue • Suite 101 • Fort Smith, AR 72901 • (479) 242-4685

HW HAWKINS & WEIR
ENGINEERS, INC.
Engineering Client Success

211 Natural Resources Drive • Little Rock, AR 72205

LITTLE ROCK
AR 722
11 MAR '19
PM 3 L



Ms. Bailey Taylor, Enforcement Analyst
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118-531799

