

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: MENA WWTP NPDES Permit No.: AR0036692 Monitoring Period (Month/Year): 3, 2024

No Sanitary Sewer Overflows This Monitoring Period

REPORT CODE DESCRIPTIONS

Cause(s) of SSO		Environmental Impact	Action(s) Taken		Ultimate Discharge Location
C - Construction	D - Debris	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	JV - Jet Vac	GR - Ground
EF - Equipment Failure	G - Grease	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	SL - Spread Lime	CR - Creek / Stream / River (specify)
LF - Line Failure	R - Rainfall (I&I)	OEEL - Evidence of Environmental Impact	HR - Hand Rodded	DD - Disinfected and Deodorized	DI - Ditch
PF - Power Failure	RO - Roots	NEAH - No Evidence of Adverse Health or Environmental Impact	MR - Machine Rodded	GP - Used Generator to Power Equipment	DR - Drop Inlet
V - Vandalism			PN - Public Notification		PA - Paved Area
			EN - Referred to Engineering		CB - Contained in Building

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
Mid south Lift station	3/25/24	3/26/24	5000	r	oeel	SL	CR
Titsworth manhole #7	3/25/24	3/26/24	500	R	NEAH	SL	CR
Titsworth manhole #6	3/25/24	3/26/24	1000	R	NEAH	SL	CR
Titsworth manhole #5	3/25/24	3/26/24	500	R	NEAH	SL	CR
Reeves & Tyler manhole #536	3/25/24	3/26/24	500	R	NEAH	SL	PA
Street performance manhole #715	3/25/24	3/26/24	500	R	NEAH	SL	CR
Wicks & Averitt manhole #7	3/25/24	3/26/24	1000	R	NEAH	SL	CR
Church & Chas manhole #518	3/25/24	3/26/24	500	R	NEAH	SL	GR
Church manhole #519	3/25/24	3/26/24	1000	R	NEAH	SL	GR
Wood Prop. main Taux #2	3/25/24	3/26/24	3000	R	NEAH	SL	CR
Old sewer plant midland #5	3/25/24	3/28/24	45000	R	OEEL	SL	CR
Midland manhole #6	3/25/24	3/28/24	95000	R	OEEL	SL	CR

[Signature]
Signature of Cognizant or Ranking Official

1 Apr 24
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD to:
ADEQ Office of Water Quality ♦ 5301 Northshore Drive ♦ North Little Rock, AR 72118