

Wastewater

To: Lawrence, Myrl
Subject: progress report

Myrl,

With reference to permit for AR0036692, Mena Wastewater plant section permit compliance schedule page 1 part lb.
The attached is a list of 1 year bio monitoring, passing lethal and sublethal on both species.

Respectfully,

 10 SEP 18

Mike Spencer
WWTP Supervisor.

Facility: Mena WWTP

Summary of Submitted Test Information

(Summary of Wet Tests)

Test No.	Test Date	Test Species	NOEC Survival	NOEC Sublethal
1	06/20/17	Ceriodaphnia dubia	100%	100%
2	06/20/17	Pimephales promelas	100%	100%
3	09/26/17	Ceriodaphnia dubia	100%	100%
4	09/26/17	Pimephales promelas	100%	100%
5	12/14/17	Ceriodaphnia dubia	100%	100%
6	12/14/17	Pimephales promelas	100%	100%
7	03/20/18	Ceriodaphnia dubia	100%	100%
8	03/20/18	Pimephales promelas	100%	100%
9	06/19/18	Ceriodaphnia dubia	100%	100%
10	06/19/18	Pimephales promelas	100%	100%
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				