From:	Brooks, Matthew (Ash Grove)
To:	SSOADEQ
Cc:	McMahon, Craig (Ash Grove); Spicer, Aaron (AshGrove)
Subject:	Ash Grove Cement Company 24 Hour Initial Report
Date:	Friday, September 18, 2020 3:46:39 PM

Dear Sir or Madam,

Ash Grove Cement Company (Ash Grove) holds a NPDES permit (permit number: AR0042846). This permit regulates three outfalls, which flow into French Creek. On September 8th, at 9:05 A.M., a Fecal Coliform sample was taken from Outfall 003. This sample was for the monthly sample for September as required by Ash Grove's NPDES permit. Results of this sample were reviewed for the first time by Ash Grove personnel at 12:00 P.M. on September 18th, and the results indicated that the Fecal Coliform had a results greater than 2,420 colonies/100 mL. This is above the daily maximum limit of 2,000 colonies/100 mL found in Part I of Ash Grove's NPDES permit. Ash Grove is investigating its systems and will detail the results in our 5 day report.

Please let me know if you have any questions. A written report will follow within the next 5 days.

Respectfully,

Matthew Brooks
Environmental Engineer I

Ash Grove Cement Company
A CRH Company
4343 Hwy 108 Foreman, AR 71836
P: 870-542-3032
M: 316-516-5736
F: 870-542-3026

www.ASHGROVE.com