From:	Brooks, Matthew (Ash Grove)
To:	SSOADEQ
Cc:	McMahon, Craig (Ash Grove); Spicer, Aaron (AshGrove)
Subject:	Ash Grove Cement Company 24 Hour Initial Report
Date:	Friday, October 23, 2020 4:21:47 PM

Dear Sir or Madam,

Ash Grove Cement Company (Ash Grove) holds a NPDES permit (permit number: AR0042846). This permit regulates three outfalls, which flow into French Creek. On October 22nd, at 9:35 A.M., a Fecal Coliform sample was taken from Outfall 003. Results of this sample were reviewed for the first time by Ash Grove personnel at 3:48 P.M. on October 23rd, and the results indicated that the Fecal Coliform had a results of 4,800 MPN/100 mL. This is above the daily maximum limit of 2,000 colonies/100 mL found in Part I of Ash Grove's NPDES permit. Ash Grove is investigating its systems and will detail the results in our 5 day report.

Please let me know if you have any questions. A written report will follow within the next 5 days.

Respectfully,

Matthew Brooks
Environmental Engineer I

Ash Grove Cement Company
A CRH Company
4343 Hwy 108 Foreman, AR 71836
P: 870-542-3032
M: 316-516-5736
F: 870-542-3026

www.ASHGROVE.com