

Lawrence, Myrl

Subject: FW: Ash Grove Cement Company 24 Hour Initial Report

From: Brooks, Matthew (Ash Grove) [<mailto:matthew.brooks@ashgrove.com>]

Sent: Wednesday, May 5, 2021 3:01 PM

To: SSOADEQ

Cc: McMahon, Craig (Ash Grove); Spicer, Aaron (AshGrove)

Subject: Ash Grove Cement Company 24 Hour Initial Report

Dear Sir or Madam,

Ash Grove Cement Company (Ash Grove) holds a NPDES permit (permit number: AR0042846). This permit regulates three outfalls, which flow into French Creek. On May 5th, at 9:46 A.M., a pH sample was taken from Outfall 001. The results indicated that the pH had a value of 9.1. This is above the daily maximum limit of a pH of 9.0 found in Part I of Ash Grove's NPDES permit. Ash Grove is investigating its systems.

Please let me know if you have any questions. A written report will follow within the next 5 days.

Respectfully,

Matthew Brooks
Environmental Engineer I

Ash Grove Cement Company
A CRH Company
4343 Hwy 108 Foreman, AR 71836
P: [870-542-3032](tel:870-542-3032)
M: [316-516-5736](tel:316-516-5736)
F: [870-542-3026](tel:870-542-3026)

www.ASHGROVE.com