

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0042846 **Discharge Number:** Outfall 003
Facility: Ash Grove Cement Company
Address: 4343 Highway 108
City: Foreman **State:** Arkansas **Zip:** 71836
Contact: Craig McMahon **Phone:** 870-542-3020

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/30/2022	Fecal Coliform	1600	Colonies/100 mL	Monthly Average: 1,000

We feel this problem was due to:

~~Chlorine running out in the wastewater treatment plant.~~


We plan on correcting the problem in this manner:

~~Chlorine has been added, and the inspection frequency has been increased to weekly.~~


Time estimated that it will take to correct problem:

~~May's sample result is back in compliance.~~

Sincerely,



 Submitted By:



 Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)