

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit: AR0042846 Discharge Number: 003B-A

Facility: Ash Grove Cement Company

Address: 4343 Highway 108

City: Foreman State: AR Zip: 71836

Contact: Craig McMahon Phone: 870-542-3020

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/31/2018	BOD	Daily Avg	18.4	10 mg/l
5/31/2018	BOD	Max	18.4	15 mg/l

We feel this problem was due to: Inadequate aeration.

We plan on correcting the problem in this manner: Increase aeration time for BOD.

Time estimated that it will take to correct problem: Two weeks. Junes DMR results have returned, BOD is back within the accepted range.

Sincerely,



Authorized Signature

6-18-18

Date