



# ARKANSAS

## ENERGY & ENVIRONMENT

April 12, 2022

Honorable Kevin Smith, Mayor  
City of Helena-West Helena  
P.O. Box 248  
Helena-West Helena, AR 72342

email: [mayor@helena-westhelena.us](mailto:mayor@helena-westhelena.us)  
[cityclerk@helea-westhelena.us](mailto:cityclerk@helea-westhelena.us)

**RE: NPDES Permit Number: AR0043389, AFIN: 54-00083  
CAP Response**

Dear Mayor Smith:

The Division of Environmental Quality (DEQ) received and reviewed the Corrective Action Plan (CAP), dated March 4, 2022, for the above referenced facility. The CAP was deemed adequate with the following comments:

- DEQ has some concerns over the use of PVC pipe and the durability of the material considering a tree has fallen on the pipe and it is exposed. The pipe should be inspected regularly and records of the inspections should be kept at the facility.
- Please notify DEQ when the long term repair of the pipe has been completed.

Please continue with the corrective actions listed in the CAP. If something should change with the CAP, please notify DEQ immediately.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0630 or you may e-mail me at [allen-daniel@adeq.state.ar.us](mailto:allen-daniel@adeq.state.ar.us).

Sincerely,

A handwritten signature in cursive script that reads "Leslie Allen-Daniel".

Leslie Allen-Daniel  
Enforcement Coordinator, DEQ, OWQ  
5301 Northshore Drive, North Little Rock, AR 72118

Cc: Kenneth Weiland P.E. [kensw@sbcglobal.net](mailto:kensw@sbcglobal.net)