

July 31, 2013

Terry McGinister, General Manager Helen Municipal Water and Sewer System 702 Cherry Street Helena, AR 72342

RE: NPDES Permit Number AR0043389

NPDES Permit Effluent Violations

AFIN 54-00083

Dear Mr. McGinister:

A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending June 2013:

Discharge Number	Parameter	Violation	Limit
001-A	Oxygen, Dissolved (DO) Inst. Min.	1.6	2

The Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of effluent violations. Any violation of your permit could result in enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. We maintain records of all violations, non-compliance reports and correspondence documenting corrective action, should enforcement action be necessary.

Thank you for your attention to this matter. If you have any questions or concerns, please feel free to contact me at 501-682-0630 or e-mail at layher@adeq.state.ar.us.

Sincerely,

April Layher

Enforcement Analyst

Water Division, Enforcement Branch