

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0043389 **Discharge Number:** 001-A-Monthly

Facility: Helena Municipal Water and Sewer System

Address: Hwy 44 & Phillips Road 301

City: Helena **State:** AR **Zip:** 72342

Contact: Benzene Collier **Phone:** 870-816-8246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading Value	Permit Limits
August, 2019	BOD	364.6 Monthly Average	354.0 Monthly Average

We feel this problem was due to: Equipment failure on fan in the building causing pump to run continuously a high flow

We plan on correcting the problem in this manner: Regreased the fan and added another fan to help keep the pump cool

Time estimated that it will take to correct the problem/s: We completed repairs September 1st and add another fan

Sincerely,


 Authorized Signature

9/20/19
 Date