

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 6/01/2017 - 6/30/2017

FROM: City of Helena
Hwy 44 & Phillips Road 301
Helena, AR 72342

DATE: 7/20/17

PERMIT #: AR0043389

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded the 7 day geo permit values during June.

3. CAUSE FOR NON-COMPLIANCE:

We had problems with pump equipment and cooling at the station. Caused the pump to stay on too long & sometimes not come on at all.

4. DURATION OF NON-COMPLIANCE:

The non compliance description above took place between June 6th-10th, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

We worked on the pumps and fixed the fans; we had to call an electrician to fix the problem.

SIGNATURE: 