

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0043389

Discharge Number: 001-A-Monthly

Facility: Helena Municipal Water and Sewer System

Address: Hwy 44 & Phillips Road 301

City: Helena

State: AR

Zip: 72342

Contact: Benzene Collier

Phone: 870-816-8246

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
September 24, 25, 26th, 2018	Fecal Coliform	1,565 col/100mls 7 Day Geometric	400 col/100mls 7 Day Geometric

We feel this problem was due to:

Storm and equipment failure

We plan on correcting the problem in this manner:

Monitor the station more closely, have a By-pass pump at the station (for backup) We are also repair tank and pumps for lift station #6

Time estimated that it will take to correct the problem/s:

The main pump is back-up & running; By-pass pump (on stand by). The pumps are still in the shop.

Sincerely,


Authorized Signature

10/18/18
Date