

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0043389 Discharge Number: 001-A Monthly

Facility: Helena Municipal Water & Sewer System

Address: Hwy 44 & Phillips Road 301

City: Helena State: AR Zip: 72342

Contact: Oscar Donaby Phone: 870-753-8528

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12/2022	BOD	585.15lb/d Mo. Avg		425.3lb/d limit
12/2022	TSS	1,433.0lb/d Mo. Av		1,276lb/d limit

We feel this problem was due to:

Flow rate was high due to heavy rainfall

We plan on correcting the problem in this manner:

Adjust flow through pump station as needed.

Time estimated that it will take to correct problem:

Problem has already been fixed.

Sincerely,

Oscar Donaby

Authorized Signature

1/27/2023

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)