

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
6301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0043389 Discharge Number: 001-A-Monthly

Facility: Helena Municipal Water and Sewer System

Address: Hwy 44 & Phillips Road 301

City: Helena

State: AR

Zip: 72342

Contact: Oscar Donaby

Phone: 870-753-8528

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Oct. 26,27,29th, 2021	BOD	781.4 lb/d Mo.Avg	32.9 mg/L Mo.Avg	425.3 lb/d & 30 mg/L Mo.Avg limits
Oct. 26,27,29th, 2021	TSS	2243.7 lb/d Mo.Avg	94.7 mg/L Mo.Avg	3276 lb/d & 90 mg/L Mo.Avg limits

We feel this problem was due to:

Started flowing again at the end of the month. Low number of days affected the Avg. for the month.

We plan on correcting the problem in this manner:

Problem should fix itself now that it's flow rate is right.

Time estimated that it will take to correct the problem/s:

Problem is already fixed.

Sincerely,

Oscar Donaby
Authorized Signature

11/23/2021
Date