

Helena Municipal Water & Sewer

702 Cherry Street
Helena-West Helena, Arkansas 72342

Owned and operated by the
City of Helena-West Helena

870-817-7460 Fax 870-338-7477

Aug 14, 2015

NPDES Enforcement Section
Arkansas Dept of Pollution Control
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Permit # AR0043389

Gentlemen:

Please find enclosed Discharge Monitoring Report and Sanitary Overflow Report for the month of July 2015.

Sincerely,

Ken Fratesi
Manager

Enclosure

NON-COMPLIANCE NOTIFICATION

FROM: Helena Municipal Water & Sewer System
702 Cherry Street
Helena, AR 72342

DATE: 8/11/2015

PERMIT #: AR0043389

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded the 7 Day Geometric mean.

3. CAUSE FOR NON-COMPLIANCE:

Sampling Chamber Needs Cleaning

4. DURATION OF NON-COMPLIANCE:

The Fecal Coliform exceeded the 7 Day Geometric mean on July 21st, 2015.

5. CORRECTIVE ACTION BEING TAKEN:

Cleaning Sampling Chamber

SIGNATURE: _____

Ken Jantzen
8-14-2015

Helena Municipal Water and Sewer System

Owned and Operated by the City of Helena-West Helena

702 Cherry Street

Helena, Arkansas

72342

MEMPHIS TN 380

14 AUG 2015 PM 1 1



NPDES Enforcement Section
Arkansas Dept of Pollution Control
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118-531799

