



ROGERS POLLUTION CONTROL FACILITY

"Serving Rogers - Protecting Our Environment"

March 29, 2017

Bryan Leamons Water Division
NPDES Permits Branch
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118-5317
Via Email leamons@adeq.state.ar.us

Permit Number: AR0043397; Chlorine overfeed notification

To whom it may concern:

On March 28, 2017 at 2:10 PM our grab sample for Chlorine residual indicated .46 mg/L. We immediately took another sample and a duplicate at 2:30 PM which indicated .50 and .52 respectively.

We assessed our automated feed system was struggling with the abnormal flows from I and I and moved the feed point from our contact chamber to our filters to allow more contact time. Our online meter showed immediate results. We took another grab sample at 4:09 PM to confirm we were at .1 mg/L. The heavy flows also caused us to use more CL2 than anticipated and our delivery truck ran late. This resulted in a period between 8:30 and 12:30 where there was no feed. As soon as the Truck arrived we connected the new tank and feed resumed.

I attempted to call Jason Bolenbough, Bryan Leamons, and Garrett Grimes to report the incident verbally and left a voice mail for all three. I am following up with this memo.

Yours truly,

A handwritten signature in black ink that reads "Todd Beaver". The signature is written in a cursive style.

Todd Beaver
Plant Manager