

Anderson, Alan

From: Todd Beaver <ToddBeaver@RWU.ORG>
Sent: Sunday, April 30, 2017 8:52 AM
To: Anderson, Alan
Cc: David Staib; Cary Roth
Subject: 4-29-17 overflow

Follow Up Flag: Follow up
Flag Status: Flagged

Alan,

We started overflowing from high flow at 7:00 P.M. on 4/29/2017. We began taking samples and logging at that time. Our Equalization basins were full and we were putting as much water through the plant as we could without overflowing the treatment basins. This notice is intended to satisfy the 24 hour requirement since this occurred on a weekend. We will send a full report when the overflow is stopped.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378

