

Anderson, Alan

From: Todd Beaver <ToddBeaver@RWU.ORG>
Sent: Friday, April 13, 2018 8:38 AM
To: Anderson, Alan
Cc: Cary Roth; David Staib; Sean Dagestad
Subject: AR0043397 - Violation

Follow Up Flag: Follow up
Flag Status: Flagged

Alan,

Thursday 4/12/18 we exceeded our permit limit of 0.10 mg/L Total Residual Chlorine. The sample collected at 1104 had 0.92 mg/L TRC. I collected again at 1125 and the concentration had dropped to 0.06 mg/L TRC.

My investigation indicates personnel were cleaning one of our tertiary filter backwash channels with bleach at the time of the sample. All of the personnel say they didn't put the bleach in the effluent water side of the filter. This morning there is what algae on the effluent side of the filter. It was a windy day and it's possible enough of the powder was blown over to cause the spike. We will put this in our notes section on our filter work order to wait for a day when the wind isn't blowing to prevent future issues.

Please accept this email as our required notification. If you have further questions or comments, please call or email.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378

