

Anderson, Alan

From: Johnny Lunsford <JohnnyLunsford@RWU.ORG>
Sent: Monday, May 14, 2018 1:59 PM
To: Anderson, Alan
Cc: Brent Dobler; Brian Sartain; Todd Beaver; Earl Rausch
Subject: Collapsed 30" Sewer Main

We would like to report what we preliminarily believe is a collapsed 30" parallel sewer main in the City of Rogers. The approximate location is west of 2004 S Promenade Blvd. Since it is a parallel sewer and is tied to an adjacent 24" parallel line in several locations, it appears that there has not been any release of sewage from this pipe. From what we can tell, the sewer in the 30" sewer main is simply backing up and flowing into the 24" inch line at one of these connections. The pipe in question is 18 feet deep and all we have been able to identify with our camera equipment (before rock inhibits us, or we go underwater) is crystal clear water running inside the pipe downstream of the believed collapse. At this time, it appears we have inflow only and no outflow. This is one of those projects where we simply are not able to see everything we would like to see and will not know until it is uncovered. As soon as we have this area exposed we will know what needs to be reported.