

November 21, 2022

Brent Dobler, Utility Superintendent City of Rogers 4300 Rainbow Road Rogers, AR 72758

**RE:** Permit Number: AR0043397, AFIN: 04-00155

**Effluent Violation Warning Letter** 

Dear Mr. Dobler:

A review of the Permit file for the above mentioned facility for the period of October 1, 2019 through October 31, 2022 reveals the following compliance issues:

email: brentdobler@rogersar.gov

The facility has reported <u>7 effluent violations</u> of Part I, Section A of Permit No. AR0043397:

DMR End Date	Disch- Desig	Parameter Desc	Reported DMR Value	Limit Value
10/31/2019	001-B	Chlorine, total residual (INST MAX, mg/L)	0.85	.1
04/30/2020	001-B	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	2.27	2
04/30/2020	001-B	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	7.1	4.5
11/30/2020	001-B	Chlorine, total residual (INST MAX, mg/L)	1.28	.1
12/31/2020	001-B	Chlorine, total residual (INST MAX, mg/L)	0.34	.1
05/31/2022	001-B	Chlorine, total residual (INST MAX, mg/L)	0.29	.1
07/31/2022	001-B	Chlorine, total residual (INST MAX, mg/L)	0.34	.1

Non-compliance reports with corrective actions were received by the Division. Any violation of your Permit is subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0840, or you may e-mail me at <a href="mailto:christina.mccutcheon@adeq.state.ar.us">christina.mccutcheon@adeq.state.ar.us</a>.

Sincerely,

Christina McCutcheon Enforcement Analyst, DEQ, OWQ 5301 Northshore Drive, North Little Rock, AR 72118

cc: Todd Beaver, Plant Manager, toddbeaver@rogersar.gov