

March 4, 2021

Brent R. Dobler, Utility Sup City of Rogers 4300 Rainbow Road Rogers, AR 72758

RE: NPDES Permit Number: AR0043397, AFIN: 04-00155

Permitted Effluent Limitation Violations

Dear Mr. Dobler,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 2 violations of Part I, Section A of NPDES Permit No. AR0043397 during the review period. DEQ requires the City of Rogers to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

email: toddbeaver@rogersar.gov

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0840 or you may e-mail me at christina.brown@adeq.state.ar.us.

Sincerely,

Christina Brown
Enforcement Analyst
Office of Water Quality

DMR End Date	Disch- Desig	Parameter Desc	Reported DMR Value	Permit Limit
11/30/2020	001-B	Chlorine, total residual (INST MAX, mg/L)	1.28	.1
12/31/2020	001-B	Chlorine, total residual (INST MAX, mg/L)	0.34	.1