

January 16, 2020

Brent R. Dobler, Utility Superintendent
City of Rogers
4300 Rainbow Road
Rogers, AR 72785

RE: NPDES Permit Number AR0043397, AFIN 04-00155
Corrective Action Plan

Dear Mr. Dobler:

The Division is in receipt of the Corrective Action Plan (CAP) dated January 15, 2020. The CAP has been reviewed and has been deemed to be inadequate with the following comments:

1. The submitted CAP is actually a Non Compliance Report. Therefore, no CAP has been submitted.
2. An evaluation of the current permitted treatment system for compliance within the requirement of the permit was not submitted.
3. The actions to be taken to correct, and prevent the recurrence of the effluent violations was not submitted.
4. A milestone schedule for compliance with the permit effluent limits, with a final date of compliance not to exceed February 28, 2021 was not submitted.

The Division request that the City of Rogers submit a CAP by February 15, 2020 to address the effluent issues.

A link to the CAP request is provided for your convenience.

CAP link:

http://www.adeg.state.ar.us/downloads/WebDatabases/PermitsOnline/NPDES/EnforcementReports/AR0043397_CAP%20request_20200108.pdf

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0667 or you may e-mail me at gavin.gray@adeq.state.ar.us

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch