

JUN 19 2017

Todd Beaver, P.E. City of Rogers 4300 Rainbow Rd. Rogers, AR 72758

Re: NPDES Permit Number AR0043397, AFIN 04-00155

Dear Mr. Beaver:

The Department is in receipt of your request dated June 5, 2017 regarding Total Residual Chlorine (TRC) monitoring. The current permit (effective March 1, 2006) for this facility requires a monitoring frequency of three/week with a sample type of continuous. Condition 7 of Part III of the permit does allow for alternative monitoring methods and/or analytical instruments. The Department has no objection to the facility taking grab samples for TRC until the next issuance of NPDES individual discharge permit AR0043397. Sample type and sampling frequency will be evaluated at the time of the next permit application to determine appropriate requirements for this facility.

Thank you for your cooperation in this matter. If there are any questions concerning this submittal, please contact Jessica Temple in the Permits Branch at (501) 682-0621.

Sincerely,

Bryan Leamons, P.E.

Senior Operations Manager

Office of Water Quality

cc: Richard Healey, Branch Manager, Enforcement Branch, Office of Water Quality Jason Bolenbaugh, Branch Manager, Compliance Branch, Office of Water Quality Alan Anderson, Enforcement Analyst, Enforcement Branch, Office of Water Quality Miles Johnson, Enforcement Coordinator, Enforcement Branch, Office of Water Quality Todd Beaver, P.E., toddbeaver@rwu.org